

PNWS-AWWA | Spring Conference

City of West Linn Bolton Reservoir and Supply Main Replacement

Presented by:

Michael L. McKillip, PhD, PE

April 28, 2018

murraysmith








Project Impetus



Where is West Linn?



Project Area



Reason 1: 100-years-old

- 1915 Construction
- 2.5 MG Hopper Bottom
- 1989 Interior Liner
- 1995 Hypalon Cover



Reason 2: Undersized

Recommended replacement:

- 2008 WSMP
- 2004 Update
- 1999 WSMP





Maintenance issues:

- Failed floating cover
- Moss nuisance


Reason 3: Improve usable storage & hydraulic performance





Siting Analysis




Evaluation of alternatives



Piping and Hydraulic Improvements



Hydraulic analysis – reservoir filling



Supply main - corrosion protection

- High pressure gas main crossings
- Double bagging
- Anodes
- Test stations
- Isolation



Supply main installation

- Owner observed
 - Expertise
 - Budget
- Rock excavation



Hydraulic analysis – available volume for suction

Reservoir Water Surface Elevation	Proposed 20-ft Depth 450-ft Overflow Elev. 430-ft Floor Elev.		Proposed 25-ft Depth 450-ft Overflow Elev. 425-ft Floor Elev.		Existing 14-ft Depth 442-ft Overflow Elev. 426-ft Floor Elev.	
	Pumping	Gravity	Pumping	Gravity	Pumping	Gravity
450	3.0	4.0	2.4	4.0	--	--
445	2.0	3.0	1.6	3.2	--	--
440	1.0	2.0	0.8	2.4	1.0	2.0
435	0	1.0	0	1.6	0	1.3
430	--	0	--	0.8	--	0.6
425	--	--	--	0	--	0

Reservoir Features and Construction



Improved slope stability

Material Properties:

Crushed Rock Base Course
 Total Unit Wt. = 130 pcf
 $\phi' = 40$ degrees
 $c' = 0$

Structural Backfill
 Total Unit Wt. = 120 pcf
 $\phi' = 32$ degrees
 $c' = 0$

Improved Ground
 Total Unit Wt. = 122 pcf
 $\phi' = 29$ degrees
 $c' = 0$

Silt & Decomposed Basalt (N = 3 to 15 b/ft)
 Total Unit Wt. = 117 pcf
 $\phi' = 21$ degrees
 $c' = 0$

Decomposed Basalt (N > 15 b/ft)
 Total Unit Wt = 120 pcf
 $c' = 2,000$ psf


Soft to Hard (R2 to R4) Basalt
 Total Unit Wt = 135 pcf
 $c' = 1$ ksi

Minimum Factor of Safety Values:

Seismic = 1.1
 Static > 1.5

Seismic $k_h = 0.22$ (1/2 PGA)

Ground improvement assumes
 30% replacement volume with
 rammed aggregate piers or equivalent
 element




Foundation improvements




Vibration monitoring & pre/post surveys

Sequencing



Deep pipe considerations



100-year-old concrete



Tideflex hydraulic mixing system




Traditional drainable-frame access hatches



New “shoe box lid” access hatches



Excavation and access




Associated Improvements



Pump improvements




Pump relocation and new pump



Multimodal improvements



Skyline drive slope improvements



Pump station roof replacement



Finished roof



Careful orchestra





Q&A

murraysmith



Thank you!