



Repair or Replace? Using Inline Technology to Assess Critical Steel Transmission Mains




Presented By:
Seth McIntosh
Jeanne Finger, P.E.
Christopher Kyea
April 27, 2018



City of Spokane Water Department Overview

- Deliver up to 180 MGD to 200,000+ people
- System includes pumps, reservoirs, source wells, and over 1,000 miles of transmission and distribution pipelines ranging from 6" to 48"
 - Kalamein
 - Asbestos cement
 - Cast Iron
 - Ductile Iron
 - Steel
 - HDPE
 - PVC
 - Copper



Repair and Replacement Strategy

Problem Identification

- Institutional / Historical Knowledge
- Leak and Break Data Points




Prioritization

- Age / installation date
- Pipe material
- Opportunities in street excavations




2 Critical Transmission Mains Scheduled for Replacement

Manito Transmission Main
1.1 Miles of 24-inch Steel




57th Avenue Transmission Main
2.0 Miles of 18/24/30-inch Steel



Assessing Steel Pipe

- Corrosion
- Manufacturing defects
- Construction damage
- Third party damage



Assess: Inspection Platforms

Leak and Air Pocket Detection



SmartBall

Inline acoustic inspection platform

Wall Thickness Evaluation



PipeDiver

Inline electromagnetic inspection platform

Site Preparation

City of Spokane		WORK ACTIVITY		Water Department	DATE: 8-25-16
<input type="checkbox"/> SERVICE REQUEST	<input checked="" type="checkbox"/> WORK ORDER	<input type="checkbox"/> INSPECTION	DESCRIPTION: Inspection Access		
NUMBER: 53790		SUBMIT TO: McIntosh		DISPATCH TO: Stillman	
LOCATION DETAILS (Nearest Street Address or Intersection): 57 th @ crestline					
ORIGINATING COMMENTS: Cut In access IN 24" main					
<p>48" Round vault over access</p>			<p>Soil type dirt Gallons lost 500 depth of main 37" TO TOP</p> <p>↑ N</p>		
<input checked="" type="checkbox"/> NEW LOCATION MEASUREMENT <input type="checkbox"/> BILLABLE WORK PERFORMED FOR OUTSIDE CUSTOMER OR DEPARTMENT			Valves/Hydrants Operated WSV 15127 WSV 15125 WSV 15126 Why 8291 HWO# VWO# 55338		
17' EWC crestline			16" NPSL 57 th		

Site and Equipment Preparation



Manito SmartBall Inspection




57th Avenue PipeDiver Setup



57th Avenue PipeDiver Insertion



Electromagnetic Inspection Data Analysis




Inspection Results

Manito Transmission Main

- 202 Pipes inspected
- Zero Leaks
- Zero Electromagnetic Anomalies


57th Avenue Transmission Main

- 282 Pipes inspected
- 1 “Leak” Detected
- 3 Pipes with Electromagnetic Anomalies



Electromagnetic Inspection Results

- Pipe 11 – S Helena St
 - 1 EM corrosion anomaly
 - Approximately 20% wall loss
- Pipe 1080 - S Lee St
 - 1 EM Anomaly not characteristic of corrosion
- Pipe 1172 – S Palouse Hwy
 - 2 EM corrosion anomalies
 - Approximately 35% and 45% wall loss
- Pipe 1174
 - 3 EM corrosion anomalies
 - Approximately 50%, 50% and 45% wall loss



Pipe 11 - 57th Avenue and Helena



Pipe 11 - 57th Avenue and Helena



Pipe 1172 - 57th Avenue and Palouse



Pipe 1172 - 57th Avenue and Palouse



Pipe 1172 - 57th Avenue and Palouse




How much corrosion before a pipe fails?


Pipeline and Diameter	Number of Distressed Pipes	Maximum Operating Pressure	Nominal Wall Thickness	AWWA M11 Required Wall Thickness	Dimensions of Corrosion Until Failure
Manito 24"	0	112 psi (281 psi surge)	0.272"	?	?
57th Avenue 18"	1	86 psi	0.180"	?	?
57th Avenue 24"	0	85 psi	0.255"	?	?
57th Avenue 30"	2	75 psi	0.270"	?	?

- Internal Pressures
- External Loading
- Design Thickness Evaluation
- Three-dimensional Finite Element Analysis






Manito Transmission Main Transient Pressure Events




Manito AWWA M11 Design Check






Three-dimensional Finite Element Analysis



City of Spokane - 57th Avenue Transmission Main 30-inch Steel Pipe, 4 feet of Earth Cover



57th Avenue Transmission Main Degradation Prediction



- Leaks possible in 4 years
- Possible to detect corrosion with current technology in 15 years

Project Costs

City Efforts Applied to Project

Data Collection

- ~ 60 labor hours

Site Visit (2) Support

- ~ 56 labor hours

Taps

- 451 labor hours
- 255 equipment hours
- 172 parts (161 salvaged/reused)

Inspection Support

- 10 days of inspection (~800 labor hours)
- Traffic Control and Permits
- Night shift

Condition Assessment Contract Value

- \$507,000

Transmission Main Replacement Capital Cost Estimate

- \$3.3M Manito
- \$4.1M 57th Avenue





Thank You!

Seth McIntosh

City of Spokane Water Department

Phone: (509) 625-7859

Email: smcintosh@spokanecity.org

Jeanne Finger, P.E.

City of Spokane Water Department

Phone: (509) 625-7811

Email: jfinger@spokanecity.org

Christopher Kyea

Pure Technologies

Phone: (619) 764-5796

Email: christopher.kyea@puretechltd.com