

Bull Run
TREATMENT
PROJECTS

*Our water: Safe and abundant
for generations to come*

PORTLAND WATER BUREAU

Bull Run Treatment Projects

**Evaluation of Pre-Oxidation and
Secondary Disinfection Approaches on
DBP Formation and Taste & Odor Using
Simulated Distribution System Testing**

April 28, 2022
Anna Vosa, PE




PNWS-AWWA
Water 2022
Tacoma, WA • April 27-29

Agenda

1. Background – Portland's Bull Run Filtration Facility Project
2. Methods for Assessing Treatment Alternatives for DBPs and T&O
3. Test Results
 - Pre-oxidant comparison
 - Secondary residual (chlorine vs chloramines)
4. Summary




Thanks to thoughtful planning, Bull Run has been a source of **excellent water since 1895**



- Serves almost 1 million people
- Serves the City of Portland and 19 wholesale customers
- Uses 100 million gallons of water on an average day



Improvements
to our system
are needed to
meet national
drinking water
standards



Existing Water Quality and BRFF Treatment Goals

	Current Unfiltered Finished Water Quality Average and (Range)	BRFF Project Goal	Notes
Turbidity (NTU)	0.4 (0.2 – 3.3)	<0.1 NTU	AWOP & PSW optimization goal
TOC (mg/L)	1.0 (0.7 – 2.0)	-	Organics reduction needed to reduce DBPs
Total Chlorine Residual (mg/L)	2.2 – 2.5 mg/L at entry point >1.0 mg/L in tanks >0.5 mg/L in DS	no change	
Total Trihalomethanes (TTHM) (ug/L)	27 (16 – 48)	LRAA <40 ug/L	<50% of MCL (MCL = 80 ug/L)
Haloacetic Acids (HAA5) (ug/L)	32 (11 – 55)	LRAA <30 ug/L	<50% of MCL (MCL = 60 ug/L)

AWOP = Area Wide Optimization Program


PSW = Partnership for Safe Water


MCL = Maximum Contaminant Level

LRAA = Locational Running Annual Average

DS = distribution system

Proposed Treatment Process





Pre-oxidation

- Pre-oxidant vs no pre-oxidant
- Pre-oxidant type: ozone vs chlorine
- Pre-oxidant dose strategy

Flocculation & Sedimentation

- Coagulant type: PACl, alum, ferric sulfate
- Flocculation type and time
- Benefit of sedimentation

Filtration

- Filter loading rate
- Filter media types (anthracite vs GAC), sizes/depths

Post-Treatment & Finished Distribution

- Primary disinfection – chlorine concentration and contact time
- Secondary Disinfectant – chloramines vs free chlorine
- Corrosion Control

Purple = Treatment decisions with potential to impact DBPs, chlorine stability, and taste/odor of water in the distribution system

Bench testing approaches for evaluating DBP formation

	Formation Potential "FP"	Uniform Formation Conditions "UFC"	Simulated Distribution System "SDS"
Incubation Time	7 days	24 hours	Match max water age
Chlorine Residual Target	3-5 mg/L after 7 days	1.0±0.4 mg/L after 24 hours	Match DS residual target
Incubation Temperature	25.0±2.0°C	20.0±1.0°C	System-specific
pH	7.0±0.2	8.0±0.2	System-specific (i.e., corrosion control target)
Secondary disinfectant	n/a (free chlorine)	n/a (free chlorine)	System-specific (chlorine or chloramines)



Why Simulated Distribution System (SDS) Testing?

- Benefits of SDS Tests:
 - Most representative of expected water quality
 - Opportunity to incorporate more than THMs and HAAs:
 - Chlorine stability in bulk water over time
 - Taste testing (flavor profile analysis and flavor rating assessment)
 - Unregulated DBPs (e.g., NDMA formed during chloramination)
- Limitations of SDS testing:
 - Only considers bulk water reactions
 - × Nitrification
 - × Pipe wall effects from unlined cast iron
 - Results cannot be extended to or compared with other supplies



SDS Conditions for BRFF Pilot Study


	Secondary Residual: Chloramines	Secondary Residual: Free Chlorine
Free Chlorine Contact Period:	60 minutes	
Chlorine Residual Target after Free Chlorine Contact Period:	2.5 mg/L	2.0 mg/L
pH/Alkalinity* Target:	9.0/30	8.5/30
Treatment Chemicals	Chlorine: HASA sodium hypochlorite, 12% (NaOCl) Corrosion Control: Soda Ash (Na ₂ CO ₃) and Sodium Bicarbonate (NaHCO ₃) Chloramination: Ammonium hydroxide (NH ₄ OH)	
Simulated Distribution Incubation Period	14 days (WQ sampling at beginning, middle, and end)	
Incubation Temperature	Match seasonal terminal reservoir temp (11 – 20°C)	

*Alkalinity as CaCO₃



Bull Run Pilot Plant Filter Columns

SDS Testing Approach



Sample:

- Turbidity
- UV254 & Color
- TOC
- Temperature
- pH & alkalinity

Sample after 60 mins:

- Free & total Chlorine
- Temperature
- pH & alkalinity

Sample after 10 mins:

- Total chlorine, monochloramine, free/total NH3
- Temperature
- pH & alkalinity
- TTHM & HAA5
- Color*

Sample after 7 days:


- Total chlorine, monochloramine, free/total NH3
- Temperature
- pH
- Color*
- TTHM & HAA5*
- FPA/FRA*

Sample after 14 days:

- Total chlorine, monochloramine, free/total NH3
- Temperature
- pH
- TTHM & HAA5
- Color*
- Nitrosamines*

*Optional

Flavor Profile Analysis (FPA) and Flavor Rating Assessment (FRA)



T&O Wheel of Descriptors

FPA rates the intensity of specific characteristics – taste/aftertaste, odor, mouthfeel – identified by the taster on a scale of 0-12 (SM 2170)

FRA rates the acceptability of the water on a scale of 1-9 (SM 2160)

FRA scale


1. I would be very happy to accept this water as my everyday drinking water.
2. I would be happy to accept this water as my everyday drinking water.
3. I am sure that I could accept this water as my everyday drinking water.
4. I could accept this water as my everyday drinking water.
5. Maybe I could accept this water as my everyday drinking water.
6. I don't think I could accept this water as my everyday drinking water.
7. I could not accept this water as my everyday drinking water.
8. I could never drink this water.
9. I can't stand this water in my mouth and I could never drink it.

FPA Scale

—	(odor-free)
T	(threshold)
2	(very weak)
4	(weak)
6	
8	(moderate)
10	
12	(strong)



Flavor Profile Analysis and Flavor Rating Assessment



FPA/FRA Scoring Sheet for Drinking Water Samples

Initials AV Date 5/18/21


Sample ID	Odor		Mouthfeel		Taste and Aftertaste		FRA (1-9)	Comments
	Descriptor	FPA (0-12)	Descriptor	FPA (0-12)	Descriptor	FPA (0-12)		
1	none	0	smooth	0	chlorine chlorine	3 3	5	
2	none	0	smooth	0	none metallic aftertaste	1	1	no taste
3	none	0	smooth soft	0	earthy chlorine metallic aftertaste	1 1	3	
4	none	0	smooth	0	chlorine	1	2	

Samples include the following full treated drinking water samples (not necessarily provided in this order):

- Pilot-filtered water, coagulated with alum, pre-oxidation via pre-chlorination. Adjusted to pH 9 and containing 2.0-2.5 mg/L total chlorine residual.
- Pilot-filtered water, coagulated with alum, pre-oxidation via pre-ozonation. Adjusted to pH 9 and containing 2.0-2.5 mg/L total chlorine residual.
- PWB unfiltered tap water collected from C3LO (Lusted Outlet entry point)
- PWB unfiltered tap water collected from WQSS 71 outside Interstate

Tips for taste testing and considerations for using “simulated” water

- **All samples must be treated to drinking water standards**
- **Treatment chemicals NSF 60 or high-quality reagent-grade**
- Glassware cleaned and “chlorine-demand free”
- Consider screening taste testers beforehand
- Avoid eating/drinking 30 minutes beforehand
- Samples numbered but randomized
- Clean plastic or glass cups, no paper cups
- T&O free water and salt-free crackers in between samples






Portland WQ staff Lillian and Nick bravely tasting water samples

Results




SDS Test*	Objective	Raw (unfiltered) WQ	Filtered WQ	Incubation Temp (°C)
Test 1 (fall 2019)	<ul style="list-style-type: none"> Pre-ozone vs no pre-oxidant Anthracite vs GAC 	0.3 NTU 1.3 mg/L TOC	<0.05 NTU 0.4 – 0.6 mg/L TOC	9-13
Test 2 (spring 2021)	<ul style="list-style-type: none"> Pre-ozone vs pre-chlorine 	0.4 NTU 0.8 mg/L TOC	0.01 NTU 0.3 mg/L TOC	20
Test 3 (fall 2020)	<ul style="list-style-type: none"> Two pre-ozone doses (0.6 vs 1.2 mg/L) Secondary residual impact (chloramines vs free chlorine) 	0.5 NTU 1.7 mg/L TOC	0.01 NTU 0.6 - 0.7 mg/L TOC	20

*Coagulation with PACl for Tests 1 and 3. Coagulation with alum for Test 2.





Test 1: Pre-ozone vs no pre-oxidant (fall 2019)







Test 1: Pre-ozone vs no pre-oxidant (fall 2019)







Test 1: Pre-ozone vs no pre-oxidant (fall 2019)






Test 1: Pre-ozone vs no pre-oxidant (fall 2019)







Test 1: Pre-ozone vs no pre-oxidant (fall 2019)







Test 2: pre-ozone vs pre-chlorine (spring 2021)




Test 2: pre-ozone vs pre-chlorine (spring 2021)







Test 2: pre-ozone vs pre-chlorine (spring 2021)






Test 2: pre-ozone vs pre-chlorine (spring 2021)






Test 2: pre-ozone vs pre-chlorine (spring 2021)







Test 3: ozone dose & secondary residual (fall 2020)





Test 3: ozone dose & secondary residual (fall 2020)







Test 3: ozone dose & secondary residual (fall 2020)



Test 3: ozone dose & secondary residual (fall 2020)




Test 3: ozone dose & secondary residual (fall 2020)



Summary

- Tasters generally rated water highly
 - no major improvements or drawbacks to taste/odor associated with treatment
- Filtration greatly improved total chlorine stability
- DBP goals met with any pre-oxidant approach
 - Project includes 0.75 mg/L ozone system, but may be deferred
 - Pre-chlorination, depending on dose, may not be able to meet DBP reduction goals following a wildfire or other event that degrades raw water quality



Acknowledgements - Pilot Study Project Team



Portland Water Bureau

- **Yone Akagi** – Water Quality Group Manager
- **Kimberly Gupta** – Bull Run Supply & Treatment Manager
- **Anna Vosa** – SDS Testing Lead
- **Mac Gifford** – Pilot Operations Lead
- **Pilot Ops:** Thomas Krause, Mojtaba Azadi Aghdam, Humberto Piedra-Ruiz, Lillian Gehres, Melanie Roy
- **PWB Lab** – Christina Cotnam, Marsha Farooqui, Otilia Plesiu

BRFF
TAC

Pilot Technical Advisors

- **Issam Najm**, WQTS
- **Mark LeChevallier**, Dr. Water Consulting

Brown AND
Caldwell

Brown and Caldwell

- **Lynn Stephens**, Pilot Study Lead
- **Damon Roth**, Pilot Study and Corrosion Control
- **Mia Vijanderan**



Seattle Public Utilities WQ Lab

- **Elizabeth Cruise**
- **David Chong**



Bull Run
TREATMENT
PROJECTS

*Our water: Safe and abundant
for generations to come*

Learn More portland.gov/bullrunprojects

Thank you!

Anna Vosa, PE
anna.vosa@portlandoregon.gov