




# MEMBRANE DATA INTEGRITY PNWS-AWWA 2024 CONFERENCE




Jolyn Leslie, PE  
Engineering & Technical Services  
Office of Drinking Water



Enhance public health protection through optimizing the performance and operations of existing facilities

AWOP Map  
September 2023




# What is Data Integrity?

---

- Maintaining and ensuring accuracy and consistency of data from sample collection point until the data is used.
  - Instrument maintenance and calibration
  - Hardware/moving parts
  - Human factor

# 134 Surface Water Treatment Plants






## Filtration Technology

- BAG/CARTRIDGE
- BANK FILTRATION
- DIATOMACEOUS EARTH
- MEMBRANE
- RAPID RATE
- SLOW SAND
- UNFILTERED

## Drinking Water Region

- EA
- NW
- SW

# Drinking Water Treatment Plants



# Data Integrity in Washington State

---

- 1 2012-2013**
  - Turbidity
  - 25 rapid rate filtration plants
- 2 2014-2015**
  - Disinfection
  - 33 surface water treatment plants
- 3 2019-2024**
  - Membrane
  - 8 of 15 membrane plants (so far)

# Membrane LRV – Data Integrity Project Goals

---

- Verify plant operating within approved design parameters
- Confirm reporting representative of actual operation
- Confirm MOR current and reflects design approval limits
- Learn about/gain comfort with LRV
  - Attempt to verify number reported in SCADA (if applicable)
- Identify needed improvements in our program/internal staff training opportunities

# Alternative Filtration Technology Approval

- Established for each make/model
  - Pathogen removal credit
  - Operating Parameters
  - See alternative technology approval memo

<b>Parameter</b>	<b>Value</b>
<i>Maximum Transmembrane Pressure</i>	45 psi
<i>Maximum Flux Rate</i>	100 gal/ft <sup>2</sup> •day
<i>Quality Control Release Value</i>	0.070 psi/min
<i>Turbidity performance requirement<sup>1</sup></i>	≤ 0.10 NTU 95% of the time <sup>2</sup>
<i>WAC 246-290-660 (1)(a)(i) and (iv)</i>	Never Exceed 1.0 NTU in any measurement
<i>Direct Integrity Testing Requirement</i>	Daily <sup>3</sup>
<i>Minimum Initial Test Pressure</i>	13.6 psi
<i>Indirect Integrity Monitoring Threshold</i>	Applied to each membrane unit Particle Counts <sup>4</sup> – 30 counts/mL; or Turbidity <sup>5</sup> – 50 mNTU
<i>Automatic Shutdown of Membrane Unit<sup>6</sup></i>	Calculated Log Removal Value (LRV) <sup>7</sup> < 3.0 or Pressure Decay Test > UCL



Current raw water turbidity = \_\_\_ NTU. Current raw water temperature= \_\_\_ °C

Operating data (from SCADA) date/time:

Filter Train:	Flowrate (gpm)	Flux (gfd)*	TMP (psi)	LRV-displayed	LRV-calculated**	IFE (NTU)	Specific flux / permeability (flux/TMP)
Train 1-Cell A				NR			
Train 1-Cell B							
Train 2-Cell A				NR			
Train 2-Cell B							
Approval limits	per skid	≤100	≤ 12 (vac)	3.0	3.0	50 mNTU	

\*calculated from \_\_\_ gpm x 1440 min/day / (6500 sf/module x 3 modules)-not temperature-corrected

\*\* from most recent PDT data (see below). Using turbulent flow assumption.

Indirect integrity monitoring (make/model, PDT trigger): Hach Filtertrak 660, 50 mNTU for ≥15 min.

Alarms:

Direct integrity testing/Pressure decay test (PDT): Also called membrane integrity test (MIT). 4.8 psi min test pressure, 10 min hold time. At least daily and when triggered by indirect integrity monitoring. Each cell tested independently. Air applied to permeate/filtrate side of the membrane.

Alarms:

Most recent PDT data:

Filter Train:	Date/Time PDT	Start (psi)	End (psi)	Decay (psi/min)
Train 1-Cell A				
Train 1-Cell B				
Train 2-Cell A				
Train 2-Cell B				
Approval limits		≥4.8	≥4.8	≤0.1 psi/min***

Data to collect:

1. Operational data
2. IFE turb models, settings, maintenance
3. Direct integrity test data, most recent test ea skid
4. Observe direct integrity test
5. Pressure sensor, flow meter calibration/verification
6. Measurements for Vsys
7. Measurements for back pressure (BP)
8. Alarm setpoints

V<sub>sys</sub> (measured):

Calibration/Verification:

Pressure sensors:

Turbidimeters:

Turbidimeter settings*		Signal span (NTU)	Error Hold Mode	Comments
Raw	Hach FT660-SC200			
IFE #1	same			
IFE #2	Same			
CFE**	same			





- Memcor/Axia with Evoqua/Siemens S10N membrane modules
- Submerged system, recently upgraded modules from S10V to S10N
- Two skids (recently added third)
- 48 modules each skid
- DIT/PDT – air applied to filtrate side, daily
- Indirect integrity monitoring (PC on one train, FT660 on other)

# Findings

Filter Train:	Flowrate (gpm)	Flux (gfd)	TMP (psi)	LRV <sub>displayed</sub>	LRV <sub>calc</sub> **	IFE	Specific flux/permeability (flux/TMP)
Filter #1	225	22.48	4.24	5.60	4.97	11.5 mNTU	5.3
Filter #2	226	27.19	4.78	5.36	4.92	Displays 00	5.7
Approval limits	400	≤ 80	≤ 22	3.0	3.0	50 mNTU/30 counts/mL	

\*\* from most recent PDT data, using laminar flow assumption

Filter Train:	Date/Time PDT	Start (psi)	End (psi)	Decay (psi/min)
Filter #1	Did not record	18.8	18.4	0.19
Filter #2	11/21/19 9:41 PM	17.1	16.6	0.26
	Approval limits:	≥14.0		≤0.39




# Findings

1. Outdated MOR: no starting test pressure, old (S10V) approval limits
2. Pressure transducers never verified/calibrated\* since installation (2006)
3. Particle counter sending 4mA (flatline) signal to SCADA for 10 months-our monthly review didn't catch.
4. Operator didn't know how to find the starting/ending pressure of the last PDT. Neither did we.
5. UCL (0.39 psi/min) based on fouled membrane, permeability, 0.5 gfd. Historical plant data show 4.5 to 6.1 gfd

A screenshot of a SCADA system interface. The title is "FILTER 2 DATA". The data is as follows:

Parameter	Value
PARTICAL CNTS (>2um)	0.00 cnt/mL
PARTICAL CNTS (>5um)	0.00 cnt/mL
LOG REMOVAL VALUE (LRV)	5.36
FLUX RATE	27.19 gfd
TRANSMEMBRANE PRS.	4.78 psi
PRESSURE DECAY TEST	0.26 psi/m
FILTRATE FLOW RATE	225 gpm
TODAYS FILTRATE FLOW TOT.	16.0 K Gal
YEST. FILTRATE FLOW TOTAL	126.6 K Gal

An arrow points from the text in the findings to the "PARTICAL CNTS (>2um)" value.

# Pall Microza UNA 620A





Calibrated Annually

- Pall Microza AP-6, UNA 620A.
- Two skids, each skid has 42 modules arranged in 4 rows (10 + 11 + 11 + 10)
- Stubs for an additional 12 modules per skid.



- Filtrate flow (white arrows)
- Four filtrate headers above with common manifold
- Plant installed 2011; module replacement 2020.

Air manifold

"XR" piping

Feed lines

# Findings

Make/model: Pall Microza (AP-6, UNA 620A). Two trains, 42 modules each.

## Operating data (from SCADA)

Filter Train:	Flowrate (gpm)	Flux (gfd)*	TMP (psi)	LRV- displayed	LRV- calculated**	IFE (NTU)	Specific flux / permeability (flux/TMP)
Skid A- 10:51 am	200	12.75	6.6	4.2	4.3	0.013	2.6
Skid B- 12.45 pm	200	12.75	6.6	4.1	4.2	Not recorded	Not recorded
Approval limits	520 per skid	≤ 120	≤ 43.5	3.0	3.0	50 mNTU	

\*\*from most recent PDT data, turbulent flow assumption

## Most recent PDT data:

Filter Train:	Date/Time PDT	Start (psi)	End (psi)	Decay (psi/min)	Water temp (C)	Flowrate*** (gpm)	TMP*** (psi)
Skid A	1/6/2020 1:00 am	29.83	29.67	0.032	7.6	200	6.4
Skid B	1/6/2020 12:00 am	29.44	29.25	0.038	7.6	200	7.1
Approval limits		≥25.0		≤0.33		520	43.5



# Findings

1. PDT injects air on the feed side. We measured the filtrate side piping. Not able to verify manufacturer's  $V_{sys}$ , but we used it for LRV calculation.
2. PDT has five-minute hold. On MOR utility reporting total pressure drop, instead of psi/min.
  - PDT reported:  $\sim 0.2$  psi/min
  - Actual PDT:  $\sim 0.04$  psi/min
  - UCL (max PDT): 0.33 psi/min
3. TU5300 on IFE. Should be TU5400 (double the cost) or Lovibond 6000.
4. CFE Turbidimeter controller (SC200) set to hold the last good reading.

Monday, January 09, 2018  
10:23:14 AM  
Current User: ENGINEER

MF Skid IT Data

Total Filtrate Flow: 9.6 GPM  
Filtrate Today: 27.876 MGD  
Filtrate Yesterday: 41.269 MGD

MF Skid A							MF Skid B						
	Month	Day	Hour	Start Pressure	End Pressure	Delta Pressure		Month	Day	Hour	Start Pressure	End Pressure	Delta Pressure
IT #1 Data	1	8	1	29.83	29.67	0.16 PSI	IT #1 Data	1	8	0	29.44	29.25	0.19 PSI
IT #2 Data	1	5	7	29.73	29.57	0.16 PSI	IT #2 Data	1	5	5	29.19	29.03	0.16 PSI
IT #3 Data	1	5	5	29.76	29.60	0.16 PSI	IT #3 Data	1	5	4	29.31	29.12	0.19 PSI
IT #4 Data	1	4	0	29.89	29.67	0.22 PSI	IT #4 Data	1	4	0	30.37	30.15	0.22 PSI

ALARM STATUS  
Display Skid IT Data / U / O

Main Graphics MF Skids Data Setup Alarm Trends

# Memcor CMF with Dupont/Evoqua/Siemens M10C



- 8 trains. Each train has 90 modules
- 65 MGD design flow
- Short membrane life (4-5 yrs)
- Membranes currently being replaced: skids 1-4 complete, 5-8 remaining (replacement modules on site).
- Prefiltration: 300 micron backwashable screens
- Coagulation: ACH
- Pressure transducers verified every 6 months by Dupont
- Reaching UCL, switching from UCL to LRV



# Findings



1. Unable to view/verify IFE turbidity alarm setpoints
2. Raw/CFE turb controller: error mode set to hold the last good reading
3. CFE sample pumped from clearwell
4. MOR needs revision
5. LRV calculation uses min test pressure, should use ending pressure of last DIT test





# Zenon/ZeeWeed 500C

---



- Zeeweed 500C, installed 2007
- Veolia (prev Zenon, GE, Suez)
- PVDF (Polyvinylidene fluoride)
- Hollow fiber, outside-in
- Pore size: 0.04  $\mu\text{m}$  nominal/0.1  $\mu\text{m}$  absolute (UF)
- Submerged/vacuum (open basin)
- Two trains
- Two cells/train
- Two cassettes/ cell
- 26 elements/cassette
- 250 sf/element (6500 sf/cassette)
- DIT (MIT) pressurize the filtrate (permeate) side Done on each cell. Reporting each separately
- Indirect integrity: monitoring each train, TU5400
- Membranes never replaced!



# Findings

## Summary Information:

Make/model: Zeeweed/Zenon 500C, installed 2007. Hollow fiber, outside-in, submerged/vacuum system. Two trains. Each train has 2 groups or cells, 3 cassettes per group (6 cassettes total). Each cassette has 26 modules, also called elements. Membrane surface area 250 sf/module = 6500 sf/cassette = 39,000 sf/train. Pre-treatment: basket strainer-1mm (1000 microns) slots. Down in a vault, not self-cleaning, must be disassembled to maintain. No coagulant used. Membranes never replaced-still performing well; replacement budgeted for 2024 based on age of component parts.

Current raw water turbidity = 0.24 NTU. Current raw water temperature= 9 °C  
 Very low chlorine demand. Finished water UVT = 91.9

Operating data (from SCADA) date/time:

Filter Train:	Flowrate (gpm)	Flux <sup>1</sup> (gfd)	TMP (psi)	LRV- displayed	LRV- calculated <sup>3</sup>	IFE (NTU)	Specific flux / permeability (flux/TMP)
Train 1-Group A 2/8/2023	865	31.9	-7.48 <u>Max does not trend</u>	NR		12	NR
Train 1-Group B 2/8/2023							
Train 2-Group A 11:50 am 2/16	790	29.1	-6.2 <sup>2</sup>	NR	5.0	10	NR
Train 2-Group B 11:50 am 2/16							
Approval limits	per skid	≤100	≤ 12 (vac)	3.0	3.0	50 <u>mNTU</u>	

# Findings



1. Use manufacturer's secondary standard for weekly turbidimeter verification
2. CFE turbidity limits for all membrane plants, 95<sup>th</sup> %-ile 0.1 NTU, max 1.0 NTU; recommend to change shutdown alarm to 0.1 NTU
3. Recommendations for membrane upgrade
  - a) Install two-way or DBBV on permeate pressure transducer
  - b) Set MIT to run on entire train
  - c) Add valve on permeate/filter piping Group A to reduce pressurized volume during MIT
  - d) Program SCADA to continuously calculate LRV
  - e) Include flux & permeability trends in SCADA
  - f) Design approval needed for new replacement membranes





# Seccua Phoenix 7

---



- One unit, with two modules
- Inside-out
- Ultrafiltration
- 2150 fibers per module
- Indirect integrity monitoring  
Hach 1720E
- Did not go through prior approval by DOH, system started as a Group B (state regulated) system



**Summary Information:**

Make/model: Seccua Phoenix 7/Dizzer XLO.9MB60. Single train, 2 modules. Installed 2013. Surface area: 645 sf/module.

Operating data, previous day (9/11/2022, 11 am) (from SCADA)

Filter Train:	Flowrate (gpm)	Flux (gfd)	TMP (psi)	LRV <sub>display</sub> ed	LRV <sub>calc</sub> **	IFE	Specific flux/permeability (flux/TMP)
1	40.64	45.1	8.2	4.7		Not measured	5.5
	<b>exceeds</b>	<b>o.k.</b>	<b>o.k.</b>			CFE 0.043	
Approval limits	40	≤ 59	≤ 36	3.0	3.0	50 mNTU/30 counts/mL	

\*\*from PDT data on 9/12 (see below). Using laminar flow assumption.

Indirect integrity monitoring:

Hach TU5300: 0.043 NTU (measured after intermediate tank, need TU5400 or equivalent)

Direct integrity testing/Pressure decay test (PDT): 23 minute hold time

Filter Train:	Date/Time PDT	Start (psi)	End (psi)	Decay (psi/min)	Water temp (C)	Flowrate (gpm)- see above	TMP – see above
1	9/12/2022, 3:21 pm	22.57	21.69	0.0382 (2.64 mbar/min)	20.3	40.6	8.2
		<b>o.k.</b>		<b>o.k.</b>			
	Approval limits:	≥21.75 (1.5 bar)		≤0.25 (17 mbar/min)		40	

# Findings


## 1. Reporting issues on MOR

- Reporting flow rate rather than flux rate (gfd)
- Reporting design maximum TMP rather than the actual daily max
- Reporting normal test pressure rather than the actual minimum initial test pressure for PDT
- Reporting total pressure decay rather than decay rate

## 2. Indirect integrity monitoring – Hach 1720E is not acceptable; need to install a high resolution turbidimeter

## 3. System is a 'black box'

- Calculated PDT = 2.64 mbar/min, system reporting 5.3 mbar/min (roughly double); need to check with manufacturer and reconcile






# Pall Microza USV-6203

---





- Two trains, 6 modules each train
- FilterTrak 660 turbidimeter on each train, no CFE sample
- Installed 2009
- Prescreening with old 'package plant' and strainer
- Modules have never been replaced!



# Findings

---



1. Pressure gauges have never been calibrated
2. Online turbidimeters are not properly recording that latest calibration date
3. Incorrect monitoring and reporting of max day NTU
4. Raw water NTU sample location should be moved to common inlet header to capture a representative sample for both skids
5. Verify with Pall and/or SCADA that 50mNTU triggers a PDT
6. Verify that failed PDT triggers alarm and shut down of the plant
7. Sample delay on CT sample point (90 minutes)
8. Strongly recommend getting the TU5200 turbidimeter to compare to the online Filtertrak 660 laser turbs
9. Online chlorine analyzer did not match grab samples within 0.05 mg/L, operator and DOH also did not match

# Summary/Common Findings

---

- Pressure gauges need more attention
- IFE turbidimeter requirements
- Use correct parameters for pressure decay test – psi/min, not total psi change
- We need to update/improve our MORs
- Able to ‘mostly’ verify that plants are operating within approved design parameters
- Not always able/easy to verify LRV number reported in SCADA
- Identified needed improvements in our program/internal staff training opportunities



# Next Steps

---

- Continue with remaining membrane plants
- Final membrane commissioning guidance for new plants
- Update monthly operating reports (MOR)
- Continue looking for more opportunities on improving data integrity

Questions?

---



**Jolyn Leslie, PE**  
*Surface Water Program Engineer*  
Engineering & Technical Services  
Office of Drinking Water



@WADeptHealth



To request this document in another format, call 1-800-525-0127. Deaf or hard of hearing customers, please call 711 (Washington Relay) or email [civil.rights@doh.wa.gov](mailto:civil.rights@doh.wa.gov).